



Project Report

September 8, 2022

PROJECT TITLE	Wastewater Unit Flow Reduction Study		
FISCAL YEAR FUNDED	FY2022		
CATEGORY	Sewer		
STARTING PROJECT BUDGET	\$7,800		
CURRENT PROJECT BUDGET	\$7,800		
<input type="checkbox"/> MASTER PLAN?	<input checked="" type="checkbox"/> GROWTH RELATED?	<input type="checkbox"/> SERVICE RELATED?	

Project Description

SUMMARY STATEMENT

The NC Division of Environmental Quality (NCDEQ) 15A 2T Administrative Code provides municipalities and utilities a regulatory path to evaluate historical sewer flows per connection and request a reduction of the minimum required design sewer flow rate stipulated in the code. Generally, the sewer flow reduction for municipalities is based on Residential Equivalent Units (REU) with the intent of reducing the required rate of 360 GPD/home (120 GPD/bedroom) to a rate that is consistent with the actual sewer flows accommodated by the entity. Accordingly, the purpose of the work is to evaluate the current sewer flow rates to determine the potential flow rate reduction available and to submit a request to NCDEQ to modify the rate in accordance with the available data.

✓ Task Checklist

CHECKLIST ITEMS	
<input type="checkbox"/>	Planning
<input type="checkbox"/>	Design
<input type="checkbox"/>	Permitting
<input type="checkbox"/>	Bid
<input type="checkbox"/>	Construction Contract Award/Execution
<input type="checkbox"/>	Construction
<input type="checkbox"/>	Closeout
<input checked="" type="checkbox"/>	Study
<input type="checkbox"/>	
<input type="checkbox"/>	



Task Timelines & Comments

PROJECTED START	ACTUAL START	PROJECTED COMPLETION	ACTUAL COMPLETION	COMMENTS
None	October 27, 2021	None		See Status Summary

Status Summary

The NC Department of Environmental Quality (NCDEQ) approved lowering of the regulatory defined wastewater unit design flow for new construction within the Town from 360 gpd for a 3-bedroom, single family residence (120 gpd/bedroom) to 180 gpd (60 gpd/bedroom) on August 8, 2022. Again, the reduction approved will be for single family residences only. Accordingly, staff compiled information specific to multifamily residential units (i.e. apartments, townhomes, attached garden homes, duplexes, etc.) and thereafter provided the information to the Town's consultant on August 23, 2022. The consultant will in turn, prepare a request to NCDEQ that the design unit flow rate for multi-family units be lowered using the compiled data as the basis for the request.



Key Contacts

NAME	TITLE
Gregory K. Meshaw, PE	Town Engineer/Public Svcs Dir

EMAIL	PHONE
g.meshaw@beaufortnc.org	(252) 528-8769