

2022 Annual Drinking Water Quality Report

“Town of Beaufort”

Water System Number: “04-16-010”

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Wade Keeler at (252) 528-8754. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at the Train Depot (610 Broad Street, Beaufort, NC 28516), on the second Monday of each month.**

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Name of Utility] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by the Town of Beaufort is groundwater that comes from the Castle Hayne aquifer and there are 4 dedicated wells for the Town of Beaufort system, two wells used by the Pine Street Water Facility and two wells used by the Glenda Drive Water Facility.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environmental Quality (DEQ), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for the Town of Beaufort was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)		
Source Name	Susceptibility Rating	SWAP Report Date
Well #2	Moderate	September 2020
Well #3	Moderate	September 2020
Well #4	Moderate	September 2020
Well #5	Moderate	September 2020

The complete SWAP Assessment report for the Town of Beaufort may be viewed on the Web at:

<https://www.ncwater.org/?page=600> Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking and source water through the following actions: disposing of chemicals and paints properly, taking used motor oil to a recycling center, using proper landscape placement and practicing water conservation in and around your home.

Violations that Your Water System Received for the Report Year

During 2022, or during any compliance period that ended in 2022, we received a DBPs monitoring violation (Tier 3) that covered the time period of *January 1st, 2022 through December 31st, 2022*. We have ensured that compliance samples for DBPs will be taken from site B01, as opposed to B02, to assure this does not happen again.

NOTICE TO THE PUBLIC

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Violation Awareness Date: Oct. 6th, 2022

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the compliance period specified in the table below, we did not complete all monitoring or testing for the contaminants listed and therefore cannot be sure of the quality of your drinking water during that time.

CONTAMINANT GROUP**	FACILITY ID NO./ SAMPLE POINT ID	COMPLIANCE PERIOD BEGIN DATE	NUMBER OF SAMPLES/ SAMPLING FREQUENCY	WHEN SAMPLES WERE TAKEN (Returned to Compliance)
	D01	JANUARY, 1 ST , 2022	1/ ANNUAL (MONTH OF AUGUST)	

DISINFECTION BYPRODUCTS (DBPS)				

(HAA5)- Haloacetic Acids - include Monochloroacetic Acid, Dichloroacetic Acid, Trichloroacetic Acid, Monobromoacetic Acid, Dibromoacetic Acid.
(TTHM) - Total Trihalomethanes - include Chloroform, Bromoform, Bromodichloromethane, and Dibromochloromethane.

What should I do? There is nothing you need to do at this time.

What is being done? Compliance samples were taking from sample site B02 for the month of August 2022. State has retired sample station B02 as a compliance site. Going forward any DBPs samples will be taken from designated sample site B01.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information about this violation, please contact the responsible person listed in the first paragraph of this report.

Important Drinking Water Definitions:

- ***Not-Applicable (N/A)*** – Information not applicable/not required for that particular water system or for that particular rule.
- ***Non-Detects (ND)*** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.
- ***Parts per million (ppm) or Milligrams per liter (mg/L)*** - One part per million corresponds to one minute in two years or a single penny in \$10,000.
- ***Parts per billion (ppb) or Micrograms per liter (ug/L)*** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- ***Parts per trillion (ppt) or Nanograms per liter (nanograms/L)*** - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- ***Parts per quadrillion (ppq) or Picograms per liter (picograms/L)*** - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
- ***Picocuries per liter (pCi/L)*** - Picocuries per liter is a measure of the radioactivity in water.
- ***Million Fibers per Liter (MFL)*** - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- ***Nephelometric Turbidity Unit (NTU)*** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- ***Variances and Exceptions*** – State or EPA permission not to meet an MCL or Treatment Technique under certain conditions.
- ***Action Level (AL)*** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- ***Treatment Technique (TT)*** - A required process intended to reduce the level of a contaminant in drinking water.
- ***Maximum Residual Disinfection Level (MRDL)*** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

- **Maximum Residual Disinfection Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Locational Running Annual Average (LRAA)** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.
- **Running Annual Average (RAA)** – The average of sample analytical results for samples taken during the previous four calendar quarters.
- **Level 1 Assessment** - A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment** - A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
- **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2022.** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

REVISED TOTAL COLIFORM RULE:

Microbiological Contaminants in the Distribution System

Contaminant (units)	MCL Violation Y/N	Number of Positive/Present Samples	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	0	N/A	TT*	Naturally present in the environment
<i>E. coli</i> (presence or absence)	N	0	0	Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> <u>Note:</u> If either an original routine sample and/or its repeat samples(s) are <i>E. coli</i> positive, a Tier 1 violation exists.	Human and animal fecal waste

* If a system collecting fewer than 40 samples per month has two or more positive samples in one month, an assessment is required.

* If a system collecting 40 or more samples per month finds greater than 5% of monthly samples are positive in one month, an assessment is required.

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Antimony (ppb)	7/19/22	N	<0.003 mg/l			6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	7/19/22	N	<0.005 mg/l			0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	7/19/22	N	<0.400 mg/l			2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppb)	7/19/22	N	<0.002 mg/l			4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	7/19/22	N	<0.001 mg/l			5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	7/19/22	N	<0.020 mg/l			100	100	Discharge from steel and pulp mills; erosion of natural deposits
Cyanide (ppb)	7/19/22	N	<0.050 mg/l			200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride (ppm)	7/19/22	N	0.7 mg/l			4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (inorganic) (ppb)	7/19/22	N	<0.0004 mg/l			2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Selenium (ppb)	7/19/22	N	<0.010 mg/l			50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium (ppb)	7/19/22	N	<0.001 mg/l			0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

Arsenic: *While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.*

Nitrate/Nitrite Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Nitrate (as Nitrogen) (ppm)	2/22/22	N	<1.0 mg/l	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen) (ppm)	2/22/22	N	<0.10 mg/l	N/A		1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Nitrate: *Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.*

Asbestos Contaminant

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Total Asbestos (MFL)	2/18/20	N	ND	N/A		7	7	Decay of asbestos cement water mains; erosion of natural deposits

Synthetic Organic Chemical (SOC) Contaminants Including Pesticides and Herbicides

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
2,4-D (ppb)	7/12/22	N	<0.0001 mg/l			70	70	Runoff from herbicide used on row crops
2,4,5-TP (Silvex) (ppb)	7/12/22	N	<0.0002 mg/l			50	50	Residue of banned herbicide
Alachlor (ppb)	7/12/22	N	<0.0002 mg/l			0	2	Runoff from herbicide used on row crops
Atrazine (ppb)	7/12/22	N	<0.0001 mg/l			3	3	Runoff from herbicide used on row crops
Benzo(a)pyrene (PAH) (ppt)	7/12/22	N	<0.00002 mg/l			0	200	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	7/12/22	N	<0.0009 mg/l			40	40	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	7/12/22	N	<0.0002 mg/l			0	2	Residue of banned termiticide
Dalapon (ppb)	7/12/22	N	<0.001 mg/l			200	200	Runoff from herbicide used on rights of way
Di(2-ethylhexyl) adipate (ppb)	7/12/22	N	<0.0006 mg/l			400	400	Discharge from chemical factories
Di(2-ethylhexyl) phthalate (ppb)	7/12/22	N	<0.00132 mg/l			0	6	Discharge from rubber and chemical factories
DBCP [Dibromochloropropane] (ppt)	7/12/22	N	<0.00002 mg/l			0	200	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Dinoseb (ppb)	7/12/22	N	<0.0002 mg/l			7	7	Runoff from herbicide used on soybeans and vegetables
Endrin (ppb)	7/12/22	N	<0.00001 mg/l			2	2	Residue of banned insecticide
EDB [Ethylene dibromide] (ppt)	7/12/22	N	<0.00001 mg/l			0	50	Discharge from petroleum refineries
Heptachlor (ppt)	7/12/22	N	<0.00004 mg/l			0	400	Residue of banned pesticide
Heptachlor epoxide (ppt)	7/12/22	N	<0.00002 mg/l			0	200	Breakdown of heptachlor
Hexachlorobenzene (ppb)	7/12/22	N	<0.0001 mg/l			0	1	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene (ppb)	7/12/22	N	<0.0001 mg/l			50	50	Discharge from chemical factories
Lindane (ppt)	7/12/22	N	<0.00002 mg/l			200	200	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	7/12/22	N	<0.0001 mg/l			40	40	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
Oxamyl [Vydate] (ppb)	7/12/22	N	<0.002 mg/l			200	200	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls] (ppt)	7/12/22	N	<0.0001 mg/l			0	500	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	7/12/22	N	<0.00004 mg/l			0	1	Discharge from wood preserving factories
Picloram (ppb)	7/12/22	N	<0.0001 mg/l			500	500	Herbicide runoff
Simazine (ppb)	7/12/22	N	<0.00007 mg/l			4	4	Herbicide runoff
Toxaphene (ppb)	7/12/22	N	<0.001 mg/l			0	3	Runoff/leaching from insecticide used on cotton and cattle

Volatile Organic Chemical (VOC) Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Benzene (ppb)	7/26/22	N	<0.0005 mg/l			0	5	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	7/26/22	N	<0.0005 mg/l			0	5	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	7/26/22	N	<0.0005 mg/l			100	100	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	7/26/22	N	<0.0005 mg/l			600	600	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	7/26/22	N	<0.0005 mg/l			75	75	Discharge from industrial chemical factories
1,2 – Dichloroethane (ppb)	7/26/22	N	<0.0005 mg/l			0	5	Discharge from industrial chemical factories
1,1 – Dichloroethylene (ppb)	7/26/22	N	<0.0005 mg/l			7	7	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	7/26/22	N	<0.0005 mg/l			70	70	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	7/26/22	N	<0.0005 mg/l			100	100	Discharge from industrial chemical factories
Dichloromethane (ppb)	7/26/22	N	<0.0005 mg/l			0	5	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	7/26/22	N	<0.0005 mg/l			0	5	Discharge from industrial chemical factories
Ethylbenzene (ppb)	7/26/22	N	<0.0005 mg/l			700	700	Discharge from petroleum refineries
Styrene (ppb)	7/26/22	N	<0.0005 mg/l			100	100	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	7/26/22	N	<0.0005 mg/l			0	5	Discharge from factories and dry cleaners
1,2,4 – Trichlorobenzene (ppb)	7/26/22	N	<0.0005 mg/l			70	70	Discharge from textile-finishing factories
1,1,1 – Trichloroethane (ppb)	7/26/22	N	<0.0005 mg/l			200	200	Discharge from metal degreasing sites and other factories
1,1,2 – Trichloroethane (ppb)	7/26/22	N	<0.0005 mg/l			3	5	Discharge from industrial chemical factories
Trichloroethylene (ppb)	7/26/22	N	<0.0005 mg/l			0	5	Discharge from metal degreasing sites and other factories
Toluene (ppm)	7/26/22	N	<0.0005 mg/l			1	1	Discharge from petroleum factories
Vinyl Chloride (ppb)	7/26/22	N	<0.0005 mg/l			0	2	Leaching from PVC piping; discharge from plastics factories
Xylenes (Total) (ppm)	7/26/22	N	<0.0005 mg/l			10	10	Discharge from petroleum factories; discharge from chemical factories

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water (90 th Percentile)	Number of sites found above the AL		MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	Sept. 2020	.432 mg/l	0		1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 th percentile)	Sept. 2020	.005 mg/l	0		0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Disinfectant Residuals Summary

	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
			Low	High			
Chlorine (ppm)	N	.73 mg/l	0.21	– 2.8	4	4.0	Water additive used to control microbes

Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range Low High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb)					N/A	80	Byproduct of drinking water disinfection
Location (Ex. B01)							
2022			0.006 mg/l	<0.001 – 0.006			
2021			0.006 mg/l	0.005 – 0.006			
2020			0.003 mg/l	<0.001 – 0.003			
HAA5 (ppb)					N/A	60	Byproduct of drinking water disinfection
Location (Ex. B01)							
2022			0.006 mg/l	<0.002 – 0.006			
2021			0.006 mg/l	<0.002 – 0.006			
2020			<0.002 mg/l	<0.002 - <0.001			

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

Other Miscellaneous Water Characteristics Contaminants

Contaminant (units)	Sample Date	Your Water	Range Low High	SMCL
Iron (ppm)	7/19/22	<0.060 mg/l		0.3 mg/L
Manganese (ppm)	7/19/22	<0.010 mg/l		0.05 mg/L
Nickel (ppm)	7/19/22	<0.100 mg/l		N/A
Sodium (ppm)	7/19/22	48.4 mg/l		N/A
Sulfate (ppm)	7/19/22	<15 mg/l		250 mg/L
pH	7/19/22	7.8 mg/l		6.5 to 8.5

